



CERTIFICATE OF ANALYSIS

E6H0526

prepared for:

Housatonic Basin Sampling & Testing

Nick Bruzzi
80 Run WAY
Lee, MA 01238

Project Name: Children First Enterprises, Inc. - 1111038

Project / PO Number: 1111038-260819

Received: 08/19/2026 15:10

Reported: 08/20/2026 17:03

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

A handwritten signature in black ink, appearing to read "R. Warila", on a light grey rectangular background.

Ron Warila
Director, Environmental
08/20/2026 17:03

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Microbac Laboratories, Inc.

80 Run Way | Lee, MA 01238 | 413-776-5025 p | www.microbac.com



Bacteriological Report

I. PWS INFORMATION: Refer to your DEP Coliform Sampling Plan to help complete the PWS Information and DEP Approved Sample Site Information sections below.

PWS ID #: 1111038 PWS Name: Children First Enterprises, Inc. City/Town: Granby Class: COM ☐ NTNC ☒ TNC ☐

II. ANALYTICAL INFORMATION: Refer to your MassDEP state lab certificate for proper Lab MA Cert.# and certified methods.

Primary Lab MA Cert.#: M-MA1146 Primary Lab Name: Microbac Laboratories, Inc., Lee Subcontracted?(Y/N): N

Analysis Lab MA Cert.#: M-MA1146 Analysis Lab: Microbac Laboratories, Inc., Lee

☒ Original Report ☐ Resubmitted Report ☐ Confirmation Report(1) Reason for Resubmission: ☐ Resample ☐ Reanalysis ☐ Report Correction

(2) Collection Date of Original Sample:

TC Method	E.Coli Method	Enterococci Method	Fecal Coliform	HPC Method	Lab Sample Notes:	
SM 9223 B (Colilert-18)-2004 (18hr)	SM 9223 B (Colilert-18)-2004 (18hr)					

DEP APPROVED SAMPLE SITE INFORMATION ¹			TOTAL COLIFORM RESULT ^{4,5}	E.COLI or FECAL RESULT ^{4,5}	CHLORINE RESULT ² mg/L	HPC RESULT ² # cfu/mL	COLLECTION		ANALYSIS		COLLECTED BY	LAB SAMPLE ID #
Sample Type ^{1,3}	Location Code # ¹	DEP Approved SAMPLE LOCATION ¹					DATE	TIME	DATE	TIME		
RS	001	Evergreen Room Gym	Absent	Absent			08/19/2026	06:32	08/19/2026	16:15	Logan Gould	E6H0526-01

¹ DEP Sample Type, Location Code#, and DEP Approved Sample Site Location must correspond to the sample information on your DEP Total Coliform Sampling Plan² SWTR systems: HPC samples shall be taken at the same distribution sites and at the same time as total coliform, whenever chlorine residual is not detected at the sample site.³ Sample Type: RS-Routine Distribution Sample, RO-Original Site Repeat, UR-Upstream Repeat, DR-Downstream Repeat, AR-Additional Repeat, RW-Raw Water, PT-Plant Tap, SS-Special Sample⁴ Report as #/100mL, P (present), A (absent), or Too Numerous To Count: TNTC-I (invalid) or TNCT-P (present).⁵ Collect appropriate number of repeat samples within 24 hours of laboratory notification for coliform-positive or invalid samples. Notify DEP of any routine or repeat E.Coli or fecal positive results by the end of the business day.

I certify under penalties of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best extent of my knowledge.

Laboratory Authorized Signature and

Date:

08/20/2026

DEP Review Status: ☐ Accepted ☐ Disapproved Review Comments:

E 6 H 0 5 2 6

Housatonic Basin Sampling and Testing



Housatonic Basin
Sampling & Testing

[illegible]

Note: Submit via EDEP unless designated Private or otherwise noted. Email report to: Admin@HousatonicBasin.com. Lab testing shall be in compliance with all State and Federal Drinking Water and applicable regulations.